
The Role of Energy Modeling in Building Design and Construction

Peter Levy, MS, BEMP, LEED AP, CPHC


Todays Objectives


- What is energy modeling?
- What information goes into a model?
- What information comes out a model?
- How are models used to inform designs?
- What other purposes do models serve?
- How is Daylight Modeling used?


What is Energy Modeling?



- -Whole building energy simulation
- -Daylight analysis
- -Solar PV analysis
- -Life cycle analysis (LCA)








Whole Building Energy Simulation


A computational model, which includes the:

- Envelope
- Mechanical systems
- Internal loads
- Occupancy patterns
- Local annual weather

In order to predict the annual operational energy use of a building




What Goes into a Model?










What Comes out of a Model?


Annual operational energy use











REPO	ORT- BEPU Building	Utility F	erformand	e 					WE	ATHER FIL	E- Boston	MA	TMY2
	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT PANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1	ELECTRICITY KWH 88256.	0.	63931.	206.	24189.	0.	6286.	102579.	0.	0.	0.	6812.	292259
FM1	NATURAL-GAS THERM 0.	0.	0.	5753.	0.	0.	0.	0.	0.	ο.	208.	0.	5961

- A	B stell: 2019	Cab 19 to	653/37		200	9.	H			-	Ь.	0.	1	de	AB	AC	AD:	- 22
	Witness 20																	
	ST 1.65.71		1-044															
9				- 1	Hoorly Res	trox												
6				13	EM1 Hour	Report 9	Block						PMI Hou	dy Report	Block.			
				- 3	ELEC-MET	ER							FUEL-ME	TER				
8				- 7	EMI								FMI					
0			Day		Vari	Var 3	Var4	Var 5	Veci	Var 8	Var.12	Var 20	Ver 1	Var 4	Var 11	var32	Var 20:	
Ø Month	Day	Houn	Type	-3	Ughting is	Miscellan	Heating e	Cooling to	Amiliary s		Exterior to			Heating 6	Domestic	Exterior	to Total and	use è
15	1	1	1	8	2,09466	1.62166			2.50497	35.5255							0 86837.9	
88	1	1	2	- 6	2.09446	1.42166			2.50497	35.526					959.981		0 55585.2	
3	2	1.	3	8	2,09446	1,42366		1,95766		37.1329					940,571		0 78752.2	
4	1	1	4.	8	2,09446	1,42166		2.06976	251468	37,1344				86171.3			0 87152.4	
5	31	1	5	8	2.09446	1.42166			2.38497								5 79698.8	
6	1	1	6.	8	2.09445	1.42166	0.32677	1.9817	2.51124	37.1377				85347			G 86754.6	
7.	1	1	7	8	2.14473	1.43281	0.86015	2.03259	2.51462	37,1395							0 97713.5	
8	1	1	8	8	2.21666	1.49413	0.27998	1.49345	2.50497	18.9824							0 53307.9	
9	1	1	9	8	2.14115	1,50528		1,30476		18,2568		25.712					0 33539.1	
in:	1	1	10.	31	2,05597	1.50528	0	1.42022	2.50497						945,529		0 34007.1	
1	1	1	11	- 8	2,02911	1,50528		1.42228	2.50497	18 2568		25,7284			945,511		0 34325	
12	1	1	12	8	2.0219	1,50528		1.07826							943,455		942.455	
13	1		13	- 81	2,03337	1.50528	0	12	0.66225			6.85261		4337			0 44319.7	
4	2	1	14	8	2.04318	1,50528	. 0	0	0			3.54847			941.785		0 941,785	
5	1	12	15	8	2.07328	1,50528	. 0	0	. 0			3,57856					0 940,814	
6	1	1	15	- 8	2.12293	1.50528	. 0	0	.0			3,62823			940,411		0 940.491	
7	1	A	17	8	2,23985	1.50528	10	2.3133	1.59259	3,42116				69001.3			0 69971.6	
	1	1	18	8	2,18243	1,4579	17	1.32451	2,30497								0 18925.5	
19	1	1	19	8	2.14473	1.43281	12	1.61151	230497	35.5141							0 51442.9	
0	1	1	20	8	2.14475	1.45281	0.259	3,47962	2.50497	18.9759							0 42008.4	
1	1	1	21	8	2,10284	1.42166		1.58243						49781.2			0 30777.6	
12	1.	1	22		2.10284	1,42166	0/17292	1.68674	2.50497	35.5236				52060.5			0 556ZE1	
18	1	1	23	8	2.09446	1.42166	0.17484	1.55295	2.30A97	34.5221	1.7088	43.9804		40936.4			D A1878,9	
											-							

What is the Model Used For?

Inform the design

Model various energy conservation measures early in the design

-Assess potential energy savings and incremental cost to determine payback period

 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital Validate the design



Required validation



- -MEPA compliance
- -Code compliance
- -MSBA Compliance
- -Municipality Compliance
- -LEED (Certified/Certifiable)

Elective validation




- **Certification Programs**
- -LEED Certification
- -CHPS
- -Passive House

Utility Incentive Programs

- -Mass Save
- -P4P
- -NYSERDA

Often, a Project Requires all of Those Residential Tower in Boston

- Started Model in Jan 2014
- Design Assistance Modeling in SD-DD
- Utility Incentive Model in DD-CD
- Code Compliance Model at 100% CD
- LEED Model at 100% CD



What is the Model Used For?



Validate the design

Model various energy conservation measures early in the design

 -Assess potential energy savings and incremental cost to determine payback period

 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital



Elective validation

-MEPA compliance

-Code compliance

-MSBA Compliance

-Municipality Compliance

-LEED (Certified/Certifiable)

Certification Programs

-LEED Certification

-CHPS

-Passive House

Utility Incentive Programs

-Mass Save

-P4P

-NYSERDA

Modeling to Inform the Design


 Model various Energy Conservation Measures (ECMs) to assess how different design alternatives can reduce energy use.

Typical ECMs:


- Envelope (walls/roof/floor assemblies, windows, infiltration)
- HVAC equipment (system types, unit efficiencies, energy recovery ventilation, DCV, fuel switching)
- Internal Loads (Lighting Power Density, daylighting/occupancy controls)
- Occupancy patterns, setpoint controls

Informing the Design (Envelope ECMs)

Glazing U-value and SHGC



- Used lowest viable SHGC
- Did not pursue lower U-value windows
 - If shades/overhangs were viable, results would have been different



Informing the Design (HVAC ECMs)

Water Source Heat Pumps


Hybrid Heat Pumps (Hydronic Heating)

Table 2: Energy Savings

Original Selection


	Total Site (MBTU)	Cost (\$)	Source (MBTU)	Site Energy (%)	Cost (%)	Source Energy (%)
Baseline	37,437	\$1,032,321	74,103	NA	NA	NA
Whalen Hybrid 2 GPM/Ton	27,330	\$943,935	64,639	27.0%	8.6%	12.8%
Whalen Hybrid 2.5 GPM/Ton	27,332	\$944,035	64,645	V21.0%	₹8.6 %	12.8%
Whalen WSHP 2 GPM	26,487	\$955,447	64,896	29.2%	7.4%	12.4%
Whalen WSHP 2,5 GPM	26,557	\$959,891	65,173	29.1%	7.0%	12.1%
Climatemaster WSHP 2 GPM	26,448	\$952,062	64,690	~29.4%	7.8%	12.7%
Climatemaster WSHP 2.5 GPM	26,380	\$948,939	64,487	29.5%	8.1%	13.0%

- -Highest site & source energy savings
- -2nd highest cost savings
- -Didn't require running hydronic piping throughout building
- Used Climatemaster WSHP 2.5 GMP/Ton



Modeling to Inform the Design

Assess the potential operational energy savings and incremental cost of design alternatives.



In order to select ECMs that achieve greatest amount of energy savings with available capital.




What is the Model Used For?

Inform the design

Model various energy conservation measures early in the design

 -Assess potential energy savings and incremental cost to determine payback period

 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital



Required validation

Elective validation

-MEPA compliance

-Code compliance

-MSBA Compliance

-Municipality Compliance

-LEED (Certified/Certifiable)

Certification Programs

-LEED Certification

-CHPS

-Passive House

Utility Incentive Programs

-Mass Save

-P4P


-NYSERDA

Validation Modeling

Baseline Case vs

Per Code, based on:


- -ASHRAE 90.1 (2007,2010,2013)
- -IECC (2012, 2015)
- -Stretch Code (10% better than code)
- -Mass Save Baseline Document



Proposed Case

- -As Designed, based on:
- -Architectural drawings
- -MEP drawings
- -Landscape drawings
- -HVAC Narratives


																		R	OOF	TC	P A	IR HA	ND	LIN	Gι	TINL											
										5	UPPLY	FANS							RETURN	FANS								С	HILLED A	YATER	COOLIN	G COIL					
					CAF	PACITY	STATIC	0					MHEEL				STAT						W	HEEL							AIR SID	E		CHILLE	D WATE	RSIDE	
						NTROL	PRESS (IN.W.C							1			PRES (IN.W												UNITE	AT	UNITL	AT					\Box
DESIGNATION	MANUF. MODEL NUMBER			OUTSIDE AIR CFM	TYPE	RANGE(%)	TOTAL WO DIRTY FILTER	TOUNT	MODEL	S S N E	JT. F IL C	DA. UK		RPM	ВНР	MOTOR H.P.	TOTAL		TOTAL CFM	FAN QTY	MOTOR H.P.	MODEL	(NI)	TYPE	RPM	TOTAL MBH	SENS. MBH	FACE VELOC, (FPM)	(4,180	(4.)BM	DB(*F)	WB(*F)	P.D. (N. W.D.)	EWT (*F)	LWT (*f)	MAD	(DZH. TR)
AHU-1	VENTROL.	ROOF	21,000	21,000	FW		6,75	3	- :	- 5	20,7	4 14	-	3,860	(4)2,7	(4)3	3,8	2,5	6,000	2	(2)3		14	-	2,939	1,266,4	723,8	428,71	83,4	71	52,2	51,9	0,62	42	56	180,3	11,7
AHU-2	VENTROL	ROOF	21,000	21,000	FW		6.75	3	-:-	5	20.7	4 14	-	3,860	(4)2,7	(4)3	3.8	2.5	6,000	2	(2)3	-	14	-	2,939	1,266.4	723.8	428.71	83.4	71	52.2	51.9	0.62	42	56	180.3	11.7



Validation Modeling


Baseline Case Model

Identical Geometry, but all components built according to relevant code.



Proposed Case Model

Built to reflect all components of the design



=Savings (%)

Validation Modeling

Metric to measure savings:

- Site Energy
- EUI (site energy kBTU/SF)
- Source Energy
- Energy Cost
- Green House Gas Emissions

Unfortunately, no standard metric, which confuses clients to no end.

What is the Model Used For?

Inform the design

Model various energy conservation measures early in the design

 Assess potential energy savings and incremental cost to determine payback period

 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital



Required validation

Elective validation

-MEPA compliance

-Code compliance

-MSBA Compliance

-Municipality Compliance

-LEED (Certified/Certifiable)

Certification Programs

-LEED Certification

-CHPS

-Passive House

Utility Incentive Programs

Mar Save

PAP

-NYSERDA

Utility Incentives

Commercial version of Mass Save program

- Baseline code: Altered version of ASHRAE 90.1 2013/IECC 2015)
- Energy Metric: Site energy
- Pays \$/kWh saved
- Pays \$/Therms saved







2017 Baseline Document: Energy Code Base Case Overview

Prepared by: Fran Boucher (National Grid), Ryan Willingham (Eversource), Maddy Messer (DMI), and Rob Bialobrzeski (DMI)

Version Date: January 13, 2017

The Baseline Document defines base case (or baseline) parameters for projects pursuing energy savings and incentives under the Program Administrators' (PA) New Construction program(s). This document is intended to inform assumptions for New Construction applications as well as "end of life replacements". In this case, "end of life replacement" is defined as a specific age of existing equipment this has been established by the PA's in cooperation with state regulators. This document is applicable to commercial buildings and systems in these buildings.

In general, the base case for a given system or piece of equipment is defined by one of two primary methods:

State Energy Code; For equipment and systems whose performance is explicitly governed by the applicable state's building energy code, the baseline for that equipment is generally based on the

<u>Standard Practice/industry Standard</u>. For equipment and systems that are not governed by energy code the baseline is defined based on the minimum performance option that is still considered to be industry standard or standard practice within the given industry.

Note: In select cases, there are performance requirements in energy code that are below the current industry standard, as determined by the PAs. For those cases, the PAs have set the baseline requirements within this document to reflect the current industry standard. These apply for energy conservation measure (ECM) applications regardless of their inclusion or exclusion from the national model codes and state amendments. Those cases are identified in this document with a note that the baseline is different from the energy code requirement.

Guide for Energy Code baseline

Energy Code requirements vary by state. The Massachusetts energy code as of January 2, 2017 is based program of the daylor as in the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of January 2, 2017 is based program to the Massachusetts energy code as of the Massa

- i. International Energy Conservation Code IECC 2015
- ii ASHRAF 90 1-2013

for code-specific equipment; however, it does not provide every detail of the code criteria or all potential exemptions to code requirements. Where additional information or details are required, the state specific code documents/standards should be referenced for clarification.

Utility Incentives

- Utility Incentive Process
 - SD/DD Design Charrette (Potential ECMs)
 - DD Model with projected ECMs
 - Mass Save projects potential incentive \$
 - Owner decides which ECMs to pursue
 - 100% CD Model with final ECMs
 - Post Construction inspection of Installed ECMs
 - Incentives distributed







2017 Baseline Document: Energy Code Base Case Overview

Prepared by: Fran Boucher (National Grid), Ryan Willingham (Eversource), Maddy Messer (DMI), and Rob Bialobrzeski (DMI)

Version Date: January 13, 2017

The Baseline Document defines base case (or baseline) parameters for projects pursuing energy savings and incentives under the Program Administrators' (PA) New Construction program(s). This document is intended to inform assumptions for New Construction applications as well as "end of life replacements". In this case, "end of life replacement" is defined as a specific age of existing equipment this has been established by the PA's in cooperation with state regulators. This document is applicable to commercial buildings and systems in these buildings.

In general, the base case for a given system or piece of equipment is defined by one of two primary methods:

State Energy Code: For equipment and systems whose performance is explicitly governed by the

Standard Practice/Industry Standard: For equipment and systems that are not governed by energy code, the baseline is defined based on the minimum performance option that is still considered to be industry standard or standard practice within the given industry.

Note: In select cases, there are performance requirements in energy code that are below the current industry standard, as determined by the PAs. For those cases, the PAs have set the baseline requirements within this document to reflect the current industry standard. These apply for energy conservation measure (ECM) applications regardless of their inclusion or exclusion from the national model codes and state amendments. Those cases are identified in this document with a note that the baseline is different from the energy code requirement.

Guide for Energy Code baselines

Energy Code requirements vary by state. The Massachusetts energy code as of January 2, 2017 is based program of two patients and program baselines:

i. International Energy Conservation Code – IECC 2015

for code-specific equipment; however, it does not provide every detail of the code criteria or all potential exemptions to code requirements. Where additional information or details are required, the state specific code documents/standards should be referenced for clarification.


What is the Model Used For?

Inform the design

Model various energy conservation measures early in the design

 -Assess potential energy savings and incremental cost to determine payback period


 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital





LEED Minimum Energy Prerequisite / Optimize Energy Performance

Optimize Energy Performance Credit





New Construction	Major Renovation	Core and Shell	Points (except Schools, Healthcare)	Points (Healthcare)	Points (Schools)
65	4%	3%	- Y	3	
EN .	9%	5%	2	4	2
10%	RS .	7%	- 1	8	3
12%	10%	9%	- 4	6.	4
14%	12%	gric.	Š	7	\$
36%	38%	33%	6	8	6
18%	10/5	5%	7	9	7
20%	1816	17%		10	
22%	20%	79%		10	5
24%	22%	21%	10	12	1C
26%	24N	23%	in .	3\$	-11
29%	27%	26%	12	34	12
18%	16/5	15%	7	9.	7
20%	95	17%		10	1 × 1
22%	30%	39%	3	U	9
245	22%	27%	10	12	10
26%	24%	23%	18	33	41
29%	27%	26%	12	у	12
32%	30%	29%	13	15	13
35%	33%	32%	14	16.	14
58%	36%	35%	15	W	15
42%	40%	386	. 6.	18	16
46%	46%	42%	mm	19	11.000
50%	48%	47%	t u 2	20	


LEED Minimum Energy Performance / Optimize Energy Performance

- LEED V4
 - Baseline Code: ASHRAE 90.1 2010
 - Savings metric: % energy cost savings (typically)
 - Pre-requisite requires 5% energy cost savings (NC)
 - Optimize Energy Performance Credit 6%-50% (up to 18 points)

ABLE 1. Points for p	ercentage improveme	nt in energy perform	ance		
New Construction	Major Renovation	Core and Shell	Points (except Schools, Healthcare)	Points (Healthcare)	Points (Schools)
6%	4%	3%	1	3	1
8%	6%	5%	2	4	2
10%	8%	7%	3	5	3
12%	10%	9%	4	6	4
14%	12%	11%	5	7	5
16%	14%	13%	6	8	6
18%	16%	15%	7	9	7
20%	18%	17%	8	10	8
22%	20%	19%	9	11	9
24%	22%	21%	10	12	10
26%	24%	23%	11	13	11
29%	27%	26%	12	14	12
18%	16%	15%	7	9	7
20%	18%	17%	8	10	8
22%	20%	19%	9	11	9
24%	22%	21%	10	12	10
26%	24%	23%	11	13	11
29%	27%	26%	12	14	12
32%	30%	29%	13	15	13
35%	33%	32%	14	16	14
38%	36%	35%	15	17	15
42%	40%	39%	16	18	16
46%	44%	43%	17	19	-
50%	48%	47%	18	20	-

Pursued Alternative Energy Performance Metric ACP

- -Replaces Energy cost as the energy savings metric with:
 - -Source energy savings
 - -GHG emissions savings
- -Provides a more meaningful environmental metric, in which relative cleanliness of the local grid is accounted for
- -Beneficial for projects in New England, given how clean our grid is








Technical Reference

Figure 5 - Indirect Greenhouse Gas Emission Factors for Electricity in the U.S.

eGRID Regional Description	eGRID Acronym	CO2 _{eq} Emissions (kg/MBtu)
South/Central Alaska	AKGD	143.21
Most of Alaska	AKMS	67.11
Southwest US	AZNM	139.45
Southwest Coast	CAMX	70.44
Most of TX	ERCT	134.81
Most of Florida	FRCC	135.11
HI excluding Oahu	HIMS	154.03
Oahu Island	HIOA	222.70
Eastern WI	MROE	223.24
Uppor Midwest	MOOWY	more
New England	NEWE	74.94
New York City	NYCW	84.69
Long Island, NY	NYLI	157.66
Upstate NY	NYUP	39.34
Mid Atlantic	RFCE	101.31
Most of Michigan	RFCM	170.01
Ohio Valley	RFCW	166.36
CO-Eastern WY	RMPA	183.02
KS-Western MO	SPNO	189.06
TX Panhandle-OK	SPSO	166.81
Lower Mississippi	SRMV	111.95
Middle Mississippi	SRMW	215.68
SE US, Gulf Coast	SRSO	145.58
Tennessee Valley	SRTV	158.54
Virginia/Carolina	SRVC	107.69
National Average		133.49
Hadional Average		100.4

Energy Source	GHG Emission Factor (kG/Btu x 10^6)	Baseline (kg CO2 Emissions)	Proposed (kg CO2 Emissions)
Electricity	76.67	1,320,798.3	1,316,659.8
Natural Gas	53.11	1,131,715.7	611,094.3
		-	-
		-	-
		-	-
		-	-
Total		2,452,514.0	1,927,754.1
Savings			21.40%



ACP: Source Energy


Figure 1 - Source-Site Ratios for all Portfolio Manager Energy Meter Types

Energy Type	U.S. Ratio	Canadian Ratio
Electricity (Grid Purchase)	2.80	1.96
Electricity (Onsite Solar or Wind, RECs Retained)	1.00	1.00
Electricity (Onsite Solar or Wind, RECs Sold/Arbitrage)	2.80	1.96
Natural Gas	1.05	1.01
Fuel Oil (No. 1,2,4,5,6, Diesel, Kerosene)	1.01	1.01
Propane & Liquid Propane	1.01	1.04
Steam	1.20	1.33
Hot Water	1.20	1.33
Chilled Water	0.91	0.57
Wood	1.00	1.00
Coal/Coke	1.00	1.00
Other	1.00	1.00

Course Francis (LIC) - FNEDCY CTAD Double in Manager	
Source Energy (US) - ENERGY STAR Portfolio Manager	
5,7 7	

Indicate the source-to-site ratios or primary energy factors for each building energy source.

Energy Source	Source-to-Site Ratio	Baseline (Btu x 10^6)	Proposed (Btu x 10^6)
Electricity	3.14	54,093.0	53,923.5
Natural Gas	1.05	22,374.3	12,081.5
		-	-
		-	-
		-	-
		-	-
Total		76,467.3	66,005.0
Savings			13.68%



Energy Source	GHG Emission Factor (kG/Btu x 10^6)	Baseline (kg CO2 Emissions)	Proposed (kg CO2 Emissions)
Electricity	76.67	1,320,798.3	1,316,659.8
Natural Gas	53.11	1,131,715.7	611,094.3
		-	-
		-	-
		-	-
		-	-
Total		2,452,514.0	1,927,754.1
Savings			21.40%

Source Energy (US) - ENERGY STAR Portfolio Manager

Indicate the source-to-site ratios or primary energy factors for each building energy source.

Energy Source	Source-to-Site Ratio	Baseline (Btu x 10^6)	Proposed (Btu x 10^6)
Electricity	3.14	54,093.0	53,923.5
Natural Gas	1.05	22,374.3	12,081.5
		2	
		•	
Total		76,467.3	66,005.0
Savings			13.68%

Percentage Improvement Used to Determine Minimum Energy Performance Prerequisite Compliance and Optimize Energy Performance Points:

Savings	17.54%
	tuuu

New Construction	Major Renovation	Core and Shell	Points (except Schools, Healthcare)	Points (Healthcare)	Points (Schools)
6%	4%	3%	1	1	1
85	6%	5%	2	4	2
10%	6%	7%	3	5	. 3
12%	30%	9%	4	6	
mm	12%	The	mm	7	. 5
lew	148	12%	£ 0 3	6	6
lesi	36%	15%	- June	9	£:
20%	18%	17%	8	ia	В
22%	20%	1904	0	11	9.
24%	22%	21%	10	12	10
26%	24%	23%	Ti	13	11
29%	27%	26%	12	14	- 12
18%	16%	15%		9	7
20%	18%	17%	8	ia	8
22%	20%	1916	9	((9.
24%	22%	21%	10	12	10
26%	24%	23%	п	12	11
29%	27%	26%	n n	14	ta-
52%	30%	29%	- 3	15	- 0
35%	33%	32%	14	16	34
38%	36%	35%	16	17	19
42%	40%	39%	16	.19	16
46%	44%	43%	n	19	- 1:
50%	desc	47%	18	20	

What is the Model Used For?

Inform the design

Validate the design

Model various energy conservation measures early in the design

-Assess potential energy savings and incremental cost to determine payback period

 -Make informed selection of ECMs to achieve greatest amount of energy savings with available capital Required validation

Elective validation

-MEPA compliance

-Code compliance

-MSBA Compliance

- -Municipality Compliance
- -LEED (Certified/Certifiable)

Certification Programs

- -LEED Certification
- -CHPS
- -Passive House

Utility Incentive Programs

- -Mass Save
- -P4P
- -NYSERDA

Code Compliance

Code Compliance in Massachusetts


- Energy modeling is used when a project can't use prescriptive compliance path
- Baseline Code: IECC 2015 / ASHRAE 90.1 2013 (with MA amendments)
- Energy metric: Site energy
- Projects must use meet, or use less energy than the Baseline
- Massachusetts Stretch Code: Buildings >100,000 SF must use 10% less site energy than Baseline (if in a stretch code community)

Code Compliance

Table 2: Energy Savings


	Total Site (MBTU)	Site Energy (%)
Baseline	34,686	NA
Proposed	27,796	19.8%

Propose design used 19.8% less site energy than ASHRAE 90.1 2013 Baseline




Models Completed for Project

- Design Assistance Model (~15 sets of ECMs)
- Final 100% CD Proposed Case model
- LEED Baseline (ASHRAE 90.1 2010)
- Utility incentive Baseline (Altered ASHRAE 90.1 2013)
- Code Compliance Baseline (ASHRAE 90.1 2013)



Daylighting Analysis

- Types of Daylighting Analysis
- Illuminance study
 - Point in time analysis (typically 9am, 12pm, 3pm on the Solstices and equinox
- Spatial Daylight autonomy
 - Runs daylight analysis of every hour of the year, based on TMY weather file
 - Percent of occupied hours that there is adequate daylight (300 lux) such that artificial light is not needed.
 - ASE: Percent of occupied hours that there is greater than 1,000 lux, creating glare issues



What Are Daylight Models Used For

Inform the design

-Study daylight opportunities

Mitigate glare issues

Validate the design


-LEED Daylighting Credit

Daylight to Inform the Design

Large Office Building in Boston

 First floor Lobby/Café adjacent to a heavily glazed wall


 Primary concern was controlling glare in Lobby/Café without reducing daylight too much



Daylight to Inform the Design


Options Studied


- Original Design
- Reduced VLT
- Shading fins



Daylighting to Inform the Design


SDA Analysis (% of occupied hours above 300 lux)






Daylighting to Inform the Design

Glare Analysis (% of occupied hours above 1,000 lux)





Daylighting for LEED


- 3 ways to achieve daylight credit
 - SDA 300/50 (300 lux for 50% of occupied hours)
 - Illuminance
 - On site measurement options
- Only counts "Regularly occupied spaces"
- Daylighting credit was very difficult in LEED V4, but has been updated to be more achievable in LEED V4.1.

Daylighting for LEED

SDA analysis for LEED V4.1

New Construction, Core and Shell,	Hei

	Core and Shell, Schools, Retail, Data Centers, Warehouses and Distribution Centers, Hospitality	Ticulti care
The average sDA _{300/50%} value for the regularly occupied floor area is at least 40%	1 point	1 point
The average sDA _{300/50%} value for the regularly occupied floor area is at least 55%	2 points	2 points
The average sDA _{300/50%} value for the regularly occupied floor area is at least 75%	3 points	Exemplary performance



• If over 10% of regularly occupied spaces with over 1,000 Lux for 250 hours/year identify how the glare will be addressed.