# WIND DATA REPORT

# Mattapoisett Mattapoisett, Massachusetts

December 1, 2006 – February 28, 2007

Prepared for

Massachusetts Technology Collaborative 75 North Drive Westborough, MA 01581

by

Samuel A. Johnston James F. Manwell Anthony L. Rogers Anthony F. Ellis

April 18, 2007

Report template version 3.1

Renewable Energy Research Laboratory University of Massachusetts, Amherst 160 Governors Drive, Amherst, MA 01003

www.ceere.org/rerl

(413) 545-4359

rerl@ecs.umass.edu







#### NOTICE AND ACKNOWLEDGEMENTS

This report was prepared by the Renewable Energy Research Laboratory (RERL) at the University of Massachusetts, Amherst in the course of performing work sponsored by the Renewable Energy Trust (RET), as administered by the Massachusetts Technology Collaborative (MTC). The opinions expressed in this report do not necessarily reflect those of MTC or the Commonwealth of Massachusetts, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it.

Further, MTC, the Commonwealth of Massachusetts, and RERL make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods or other information contained, described, disclosed, or referred to in this report. MTC, the Commonwealth of Massachusetts, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe privately owned rights and will assume no liability for any loss, injury, or damage directly or indirectly resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

# TABLE OF CONTENTS

| Notice and Acknowledgements                   | 1  |
|---|----|
| Table of Contents                             | 2  |
| Table of Figures                              | 3  |
| Executive Summary                             | 4  |
| SECTION 1                                     | 5  |
| SECTION 1 - Station Location                  | 5  |
| SECTION 2 - Instrumentation and Equipment     | 6  |
| SECTION 3 - Data Summary                      |    |
| SECTION 4 - Graphs                            | 9  |
| Wind Speed Time Series                        | 10 |
| Wind Speed Distributions                      | 10 |
| Monthly Average Wind Speeds                   | 11 |
| Diurnal Average Wind Speeds                   | 11 |
| Turbulence Intensities                        |    |
| Wind Roses                                    | 13 |
| SECTION 5 - Significant Meteorological Events | 14 |
| SECTION 6 - Data Collection and Maintenance   | 14 |
| SECTION 7 - Data Recovery and Validation      | 14 |
| Test Definitions                              | 14 |
| Sensor Statistics                             | 16 |
| APPENDIX A - Sensor Performance Report        | 17 |
| Test Definitions                              | 17 |
| Sensor Statistics                             | 18 |
| APPENDIX B - Plot Data                        | 19 |
| Wind Speed Distribution Data                  | 19 |
| Monthly Average Wind Speed Data               |    |
| Diurnal Average Wind Speed Data.              |    |
| Wind Rose Data                                | 21 |

# **TABLE OF FIGURES**

| Figure 1 – Topographic Map Showing Mattapoisett Site LocationSource Topozone.com                | 5    |
|---|------|
| Figure 2 - Wind Speed Time Series, December 1st 2006—March 1st 2007                             | . 10 |
| Figure 3 - Wind Speed Distribution, December 1 <sup>st</sup> 2006—March 1 <sup>st</sup> 2007    | . 10 |
| Figure 4 - Monthly Average Wind Speed   | . 11 |
| Figure 5 - Diurnal Average Wind Speed, December 1 <sup>st</sup> 2006—March 1 <sup>st</sup> 2007 | . 11 |
| Figure 6 - Turbulence Intensity, December 1 <sup>st</sup> 2006—March 1 <sup>st</sup> 2007       | . 12 |
| Figure 7 - Wind Rose, December 1 <sup>st</sup> 2006—March 1 <sup>st</sup> 2007                  | . 13 |

#### **EXECUTIVE SUMMARY**

All the work presented in this Wind Data Report including installation and decommissioning of the meteorological tower and instrumentation, and the data analysis and reporting was preformed by the Renewable Energy Research Laboratory (RERL) at the University of Massachusetts, Amherst.

This report covers wind data measured at a meteorological tower installed at Mattapoisett school complex in the town of Mattapoisett, MA. Installed on January 20<sup>th</sup>, 2006, the wind monitoring station has been in continuous operation to this day. Two sets of two anemometers and one wind vane are mounted at 49 m (160.7 ft) and 38 m (124.6 ft), and an additional anemometer and vane are mounted at 20 m (65.6 ft). Reports are made on a quarterly basis; and this report is the fifth such report for Mattapoisett.

The season covered by this fifth quarterly report is December 2006 – February 2007 (winter quarter). Because of low valid data returns (58% overall) due to continuing fault from the end of the previous quarter, care is advised in comparing the results reported here with other sites that possess a full quarter's worth of data. Though the amount of missing data is minimal, it is expected that this loss will only affect this quarter slightly and that capabilities that the RERL has developed will allow for meaningful results to be produced for the final yearly report.

Additional information about interpreting the data presented in this report can be found in the Fact Sheet, "Interpreting Your Wind Resource Data," produced by RERL and the Massachusetts Technology Collaborative (MTC). This document is found through the RERL website:

http://www.ceere.org/rerl/about wind/RERL Fact Sheet 6 Wind resource interpretation.pdf

\*1 m/s = 2.237 mph.

# **SECTION 1 - Station Location**

The Mattapoisett site is located near the South Shore Marshes Wildlife Management Area in Mattapoisett, MA. Latitude and Longitude are 41° 38.11'N and 70° 50.55'W, respectively, using the NAD 83 datum. Figure 1 shows the site on a topographic map.




Figure 1 – Topographic Map Showing Mattapoisett Site Location--Source Topozone.com

## **SECTION 2 - Instrumentation and Equipment**

The wind monitoring equipment is mounted on a 49 m (164.0 ft) NRG tower. All other monitoring equipment comes from NRG Systems, and consists of the following items:

- Symphonie Data Logger
- Electrical enclosure box
- 5 #40 Anemometers, standard calibration (Slope 0.765 m/s, Offset 0.349 m/s). Two anemometers are located at 49 m (160.8 ft), two at 38 m (124.7 ft) and one at a height of 20 m (65.6 ft).
- 3 #200P Wind direction vanes. They are located at heights of 49 m (160.8 ft), 38 m (124.7 ft) and 20 m (65.6 ft) each.
- 5 Sensor booms, 54" length
- Lightning rod and grounding cable
- Shielded sensor wire

The data from the Symphonie logger is mailed to the Renewable Energy Research Laboratory at the University of Massachusetts, Amherst on a regular basis. The logger samples wind speed and direction once every two seconds. These data are then combined into 10-minute averages and, along with the standard deviation for those 10-minute periods, are put into a binary file. These binary files are converted to ASCII text files using the NRG software BaseStation®. These text files are then imported into a database software program where they are subjected to quality assurance (QA) tests prior to using the data.

## **SECTION 3- Data Summary**

A summary of the wind speeds and wind directions measured during the reporting period is included in Table 1. Table 1 includes the mean wind speeds measured at each measurement height, the maximum instantaneous wind speed measured at each measurement height and the prevailing wind direction measured at each measurement height. These values are provided for each month of the reporting period and for the whole reporting period.

**Table 1. Wind Speed and Direction Data Summary** 

| Date                  | Mean<br>Wind<br>Speed | Max<br>Wind<br>Speed | Prevailing<br>Wind<br>Direction | Mean<br>Wind<br>Speed | Max<br>Wind<br>Speed | Prevailing<br>Wind<br>Direction | Mean<br>Wind<br>Speed | Max<br>Wind<br>Speed | Prevailing<br>Wind<br>Direction |
|-----------------------|-----------------------|----------------------|---------------------------------|-----------------------|----------------------|---------------------------------|-----------------------|----------------------|---------------------------------|
| Height<br>Units       | 49 m<br>[m/s]         | 49 m<br>[m/s]        | 49 m<br>[m/s]                   | 38 m<br>[m/s]         | 38 m<br>[m/s]        | 38 m<br>[m/s]                   | 20 m<br>[m/s]         | 20 m<br>[m/s]        | 20 m<br>[m/s]                   |
| Dec 2006              | -                     | -                    | -                               | -                     | -                    | -                               | -                     | -                    | -                               |
| Jan 2007              | 6.34                  | 15.7                 | NW                              | 5.84                  | 14.3                 | NW                              | 4.66                  | 12.3                 | NW                              |
| Feb 2007              | 6.44                  | 16                   | W                               | 5.95                  | 15.2                 | W                               | 4.87                  | 13.3                 | W                               |
| Dec 2006<br>-Feb 2007 | -                     |                      |                                 |                       |                      |                                 |                       |                      |                                 |

Wind data statistics in the table are reported when more than 90% of the data during the reporting period are valid. In cases when larger amounts of data are missing, the percent of the available data that are used to determine the data statistics is noted

No measurement of wind speed or direction can be perfectly accurate. Wind speed measurement errors occur due to anemometer manufacturing variability, anemometer calibration errors, the response of anemometers to turbulence and vertical airflow and due to air flows caused by the anemometer mounting system. Every effort is made to reduce the sources of these errors. Nevertheless, the values reported in this report have an expected uncertainty of about  $\pm 2\%$  or  $\pm 0.2$  m/s, whichever is greater. Wind direction measurement errors occur due to sensor measurement uncertainty, tower effects, boom alignment measurement errors and twisting of pipe sections during the raising of a pipe tower. Efforts are also made to reduce these errors, but the reported wind directions are estimated to have an uncertainty of  $\pm 1$ -5 degrees.

A summary of the turbulence intensity and mean wind shear measured at each measurement height during the reporting period is included In Table 2. These values are provided for each month of the reporting period and for the whole reporting period.

Turbulence Intensity is calculated by dividing the standard deviation of the wind speed by the mean wind speed and is a measure of the gustiness of a wind resource. Lower turbulence results in lower mechanical loads on a wind turbine. Turbulence intensity varies with wind speed. The average turbulence intensity presented in Table 2 is the mean turbulence intensity when the wind speed at each measurement height is between 10 and 11 m/s.

Shear coefficients provide a measure of the change in wind speed with height. When data at multiple heights are available, shear coefficients,  $\alpha$ , have been determined. They can be used in the following formula to estimate the average wind speed, U(z), at height z, when the average wind speed,  $U(z_r)$ , at height  $z_r$  is known:

$$U(z)=U(z_r)\left(\frac{z}{z_r}\right)^{\alpha}$$

The change in wind speed with height is a very complicated relationship related to atmospheric conditions, wind speed, wind direction, time of day and time of year. This formula will not always provide the correct answer at any given site. Nevertheless the calculated shear coefficient, based on measurements at two heights, can be used to characterize the degree of increase in wind speed with height at a site.

The mean wind shear coefficient that is provided here is calculated based on the mean wind speeds in Table 1, where  $z_{high}$  and  $z_{high}$  are the heights of the higher and lower mean wind speeds used in the calculation and  $U(z_{low})$  and  $U(z_{high})$  are the mean wind speeds at the two heights.

$$\alpha = \log \left( \frac{U(z_{high})}{U(z_{low})} \right) / \log \left( \frac{z_{high}}{z_{low}} \right)$$

Table 2. Shear and Turbulence Intensity Data Summary

| Date               | Turbulence<br>Intensity<br>at 10 m/s | Turbulence<br>Intensity<br>at 10 m/s | Turbulence<br>Intensity<br>at 10 m/s | Mean<br>Wind Shear<br>Coefficient,<br>α |
|--------------------|--------------------------------------|--------------------------------------|--------------------------------------|---|
| Height<br>Units    | 49 m<br>[-]                          | 38 m<br>[-]                          | 20 m<br>[-]                          | Between<br>49 m and 38 m<br>[-]         |
| Dec 2006           | 0.15                                 | 0.16                                 | 0.2                                  |   |
| Jan 2007           | 0.15                                 | 0.17                                 | 0.22                                 | 0.32                                    |
| Feb 2007           | 0.18                                 | 0.22                                 | 0.23                                 | 0.31                                    |
| Dec 2006 -Feb 2007 | 0.17                                 | 0.18                                 | 0.22                                 |   |

## **SECTION 4- Graphs**

This report contains several types of wind data graphs. Unless otherwise noted, each graph represents data from 1 quarter (3 months). The following graphs are included:

- Time Series 10-minute average wind speeds are plotted against time.
- Wind Speed Distribution A histogram plot giving the percentage of time that the wind is at a given wind speed.
- Monthly Average A plot of the monthly average wind speed over a 12-month period. This graph shows the trends in the wind speed over the year.
- Diurnal A plot of the average wind speed for each hour of the day.
- Turbulence Intensity A plot of turbulence intensity as a function of wind speed. Turbulence Intensity is calculated as the standard deviation of the wind speed divided by the wind speed and is a measure of the gustiness of a wind resource. Lower turbulence results in lower mechanical loads on a wind turbine.
- Wind Rose A plot, by compass direction showing the percentage of time that the wind comes from a given direction and the average wind speed in that direction

Data for the wind speed histograms, monthly and diurnal average plots, and wind roses are included in APPENDIX B

#### **Wind Speed Time Series**




Figure 2 - Wind Speed Time Series, December 1st 2006—March 1st 2007

#### **Wind Speed Distributions**




Figure 3 - Wind Speed Distribution, December 1st 2006—March 1st 2007

#### **Monthly Average Wind Speeds**




Figure 4 - Monthly Average Wind Speed

#### **Diurnal Average Wind Speeds**




Figure 5 - Diurnal Average Wind Speed, December 1st 2006—March 1st 2007

#### **Turbulence Intensities**




Figure 6 - Turbulence Intensity, December 1st 2006—March 1st 2007

#### **Wind Roses**

# Mattapoisett Wind Rose, 49 m




Figure 7 - Wind Rose, December 1st 2006—March 1st 2007

# **SECTION 5 - Significant Meteorological Events**

Other than normal winter storm activity, there were no weather conditions that would have significantly affected wind speed or wind direction data.

#### Sources:

http://www.wunderground.com/, http://www.erh.noaa.gov/box/MonthlyClimate2.shtml

#### **SECTION 6 - Data Collection and Maintenance**

As can be seen in Figure 2, problems with the wind speed data began at the beginning of December and lasted until December 15. This fault has resulted in only 52% valid data for the month of December. 98.9 % and 99.8% valid data were collected from the 49 m anemometer set for the months of January and February, respectively. Due to the missing data during the month of December, the net data recovered was affected dramatically.

# **SECTION 7 - Data Recovery and Validation**

All raw wind data are subjected to a series of tests and filters to weed out data that are faulty or corrupted. Definitions of these quality assurance (QA) controls are given below under Test Definitions and Sensor Statistics. These control filters were designed to automate the quality control process and used many of the previous hand-worked data sets made at UMass to affect a suitable emulation. The gross percentage of data recovered (ratio of the number of raw data points received to data points expected) and net percentage (ratio of raw data points which passed all QA control tests to data points expected) are shown below.

| Gross Data Recovered [%] | 59.61 |
|--------------------------|-------|
| Net Data Recovered [%]   | 58.47 |

#### **Test Definitions**

All raw data were subjected to a series of validation tests, as described below. The sensors tested and the parameters specific to each sensor are given in the Sensor Performance Report which is included in APPENDIX A. Data which were flagged as invalid were not included in the statistics presented in this report.

**MinMax Test:** All sensors are expected to report data values within a range specified by the sensor and logger manufacturers. If a value falls outside this range, it is flagged as

invalid. A data value from the sensor listed in Test Field 1 (TF1) is flagged if it is less than Factor 1 (F1) or greater than Factor 2. This test has been applied to the following sensors (as applicable): wind speed, wind speed standard deviation, wind direction, temperature, and solar insolation.

**MinMaxT Test:** This is a MinMax test for wind direction standard deviation with different ranges applied for high and low wind speeds. A wind direction standard deviation data value (TF1) is flagged either if it is less than Factor 1, if the wind speed (TF2) is less than Factor 4 and the wind direction standard deviation is greater than Factor 2, or if the wind speed is greater than or equal to Factor 4 and the wind direction standard deviation is greater than Factor 3.

$$(TF1 < F1)$$
  
or  $(TF2 < F4 \text{ and } TF1 > F2)$   
or  $(TF2 \ge F4 \text{ and } TF1 > F3)$ 

**Icing Test:** An icing event occurs when ice collects on a sensor and degrades its performance. Icing events are characterized by the simultaneous measurements of near-zero standard deviation of wind direction, non-zero wind speed, and near- or below-freezing temperatures. Wind speed, wind speed standard deviation, wind direction, and wind direction standard deviation data values are flagged if the wind direction standard deviation (CF1) is less than or equal to Factor 1 (F1), the wind speed (TF1) is greater than Factor 2 (F2), and the temperature (CF2) is less than Factor 3 (F3). To exit an icing event, the wind direction standard deviation must be greater than Factor 4.

$$CF1 \le F1$$
 and  $TF1 > F2$  and  $CF2 < F3$ 

CompareSensors Test: Where primary and redundant sensors are used, it is possible to determine when one of the sensors is not performing properly. For anemometers, poor performance is characterized by low data values. Therefore, if one sensor of the pair reports values significantly below the other, the low values are flagged. At low wind speeds (Test Fields 1 and 2 less than or equal to Factor 3) wind speed data are flagged if the absolute difference between the two wind speeds is greater than Factor 1. At high wind speeds (Test Fields 1 or 2 greater than Factor 3) wind speed data are flagged if the absolute value of the ratio of the two wind speeds is greater is greater than Factor 2.

[ TF1 
$$\leq$$
 F3 and TF2  $\leq$  F3 and abs(TF1 - TF2)  $>$  F1 ] or [ (TF1  $>$  F3 or TF2  $>$  F3) and (abs(1 - TF1 / TF2)  $>$  F2 or abs(1 - TF1 / TF1)  $>$  F2) ]

#### **Sensor Statistics**

A summary of the results of the data collection and filtering are given in the Sensor Performance Report which is included in APPENDIX A. The following categories of information, tabulated for each sensor, are included in that report.

**Expected Data Points:** the total number of sample intervals between the start and end dates (inclusive).

**Actual Data Points:** the total number of data points recorded between the start and end dates.

**% Data Recovered:** the ratio of actual and expected data points (this is the *gross data recovered percentage*).

**Hours Out of Range:** total number of hours for which data were flagged according to MinMax and MinMaxT tests. These tests flag data which fall outside of an expected range.

**Hours of Icing:** total number of hours for which data were flagged according to Icing tests. This test uses the standard deviation of wind direction, air temperature, and wind speed to determine when sensor icing has occurred.

**Hours of Fault:** total number of hours for which data were flagged according to CompareSensors tests. These tests compare two sensors (e.g. primary and redundant anemometers installed at the same height) and flag data points where one sensor differs significantly from the other.

**% Data Good:** the filter results are subtracted from the gross data recovery percentage to yield the *net data recovered percentage*.

# **APPENDIX A - Sensor Performance Report**

# **Test Definitions**

| Test<br>Order | TestField1   | TestField2  | TestField3    | CalcField1   | Calc<br>Field2 | Calc<br>Field3 | TestType        | Factor1 | Factor2 | Factor3 | Factor4 |
|---------------|--------------|-------------|---------------|--------------|----------------|----------------|-----------------|---------|---------|---------|---------|
| 1             | T COLL TOTAL | TOOL TOTAL  | T COLI TOTALO | Calor Icia i | I ICIGE        | riciao         | TimeTest Insert | 0       |         |         | 0       |
|               | Etmp2aDEGC   |             |               |              |                |                | MinMax          | -30     |         | 0       | 0       |
|               | Etmx2aDEGC   |             |               |              |                |                | MinMax          | -30     |         | 0       |         |
|               | Etmn2aDEGC   |             |               |              |                |                | MinMax          | -30     |         |         |         |
|               | EtmpSD2aDEGC |             |               |              |                |                | MinMax          | -30     |         | 0       |         |
|               | Anem50aMS    |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | Anem50bMS    |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | Anem38aMS    |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | Anem38bMS    |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | Anem20aMS    |             |               |              |                |                | MinMax          | 0       |         |         |         |
|               | AnemSD50aMS  |             |               |              |                |                | MinMax          | 0       |         | 0       | _       |
|               | AnemSD50bMS  |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | AnemSD38aMS  |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | AnemSD38bMS  |             |               |              |                |                | MinMax          | 0       |         | 0       |         |
|               | AnemSD20aMS  |             |               |              |                |                | MinMax          | 0       |         | 0       | 0       |
|               | Vane50aDEG   |             |               |              |                |                | MinMax          | 0       |         | 0       | 0       |
|               | Vane38aDEG   |             |               |              |                |                | MinMax          | 0       |         | 0       | 0       |
| 32            | Vane20aDEG   |             |               |              |                |                | MinMax          | 0       |         | 0       | 0       |
| 50            | Turb50zNONE  |             |               |              |                |                | MinMax          | 0       |         | 0       | 0       |
| 51            | Turb38zNONE  |             |               |              |                |                | MinMax          | 0       | 2       | 0       | 0       |
| 52            | Turb20zNONE  |             |               |              |                |                | MinMax          | 0       | 2       | 0       | 0       |
| 60            | Wshr0zNONE   |             |               |              |                |                | MinMax          | -100    | 100     | 0       | 0       |
| 200           | VaneSD50aDEG | Anem50yMS   |               |              |                |                | MinMaxT         | 0       | 100     | 100     | 10      |
| 201           | VaneSD38aDEG | Anem38yMS   |               |              |                |                | MinMaxT         | 0       | 100     | 100     | 10      |
| 202           | VaneSD20aDEG | Anem20aMS   |               |              |                |                | MinMaxT         | 0       | 100     | 100     | 10      |
| 300           | Anem50aMS    | AnemSD50aMS | Vane50aDEG    | VaneSD50aDEG | Etmp2aDEGC     |                | Icing           | 0.5     | 1       | 2       | 10      |
| 301           | Anem50bMS    | AnemSD50bMS | Vane50aDEG    | VaneSD50aDEG | Etmp2aDEGC     |                | Icing           | 0.5     | 1       | 2       | 10      |
| 302           | Anem38aMS    | AnemSD38aMS | Vane38aDEG    | VaneSD38aDEG | Etmp2aDEGC     |                | Icing           | 0.5     | 1       | 2       | 10      |
| 303           | Anem38bMS    | AnemSD38bMS | Vane38aDEG    | VaneSD38aDEG | Etmp2aDEGC     |                | Icing           | 0.5     | 1       | 2       | 10      |
| 304           | Anem20aMS    | AnemSD20aMS | Vane20aDEG    | VaneSD20aDEG | Etmp2aDEGC     |                | Icing           | 0.5     | 1       | 2       | 10      |
| 400           | Anem50aMS    | Anem50bMS   |               |              |                |                | CompareSensors  | 1       | 0.25    | 3       | 0       |
| 401           | Anem38aMS    | Anem38bMS   |               |              |                |                | CompareSensors  | 1       | 0.25    | 3       | 0       |
| 500           | Amax50aMS    |             |               |              |                |                | MinMax          | 0       | 90      | 0       | 0       |
| 501           | Amax50bMS    |             |               |              |                |                | MinMax          | 0       | 90      | 0       | 0       |
| 502           | Amax38aMS    |             |               |              |                |                | MinMax          | 0       | 90      | 0       | 0       |
| 503           | Amax38bMS    |             |               |              |                |                | MinMax          | 0       | 90      | 0       | 0       |

| 504 | Amax20aMS  |  | MinMax | 0 | 90    | 0 | 0 |
|-----|------------|--|--------|---|-------|---|---|
| 510 | Amin50aMS  |  | MinMax | 0 | 90    | 0 | 0 |
| 511 | Amin50bMS  |  | MinMax | 0 | 90    | 0 | 0 |
| 512 | Amin38aMS  |  | MinMax | 0 | 90    | 0 | 0 |
| 513 | Amin38bMS  |  | MinMax | 0 | 90    | 0 | 0 |
| 514 | Amin20aMS  |  | MinMax | 0 | 90    | 0 | 0 |
| 520 | Vmax50aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |
| 521 | Vmax38aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |
| 522 | Vmax20aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |
| 530 | Vmin50aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |
| 531 | Vmin38aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |
| 532 | Vmin20aDEG |  | MinMax | 0 | 359.9 | 0 | 0 |

# **Sensor Statistics**

| Sensor       | Expected<br>Data Points | Actual<br>Data Points | % Data<br>Recovered | Hours Out of Range | Hours of Icing | Hours<br>of Fault | % Data Good |
|--------------|-------------------------|-----------------------|---------------------|--------------------|----------------|-------------------|-------------|
| Anem50aMS    | 26065                   | 15541                 | 59.624              | 0                  | 64.333         | 1.833             | 58.101      |
| AnemSD50aMS  | 26065                   | 15541                 | 59.624              | 0                  | 64.333         | 1.833             | 58.101      |
| Anem50bMS    | 26065                   | 15541                 | 59.624              | 0                  | 65.333         | 45.667            | 57.069      |
| AnemSD50bMS  | 26065                   | 15541                 | 59.624              | 0                  | 65.333         | 45.667            | 57.069      |
| Anem50yMS    | 26065                   | 15541                 | 59.624              | 0                  | 64.333         | 0                 | 58.143      |
| AnemSD50yMS  | 26065                   | 15541                 | 59.624              | 0                  | 64.333         | 0                 | 58.143      |
| Anem38aMS    | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0.833             | 58.646      |
| AnemSD38aMS  | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0.833             | 58.646      |
| Anem38bMS    | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0.667             | 58.65       |
| AnemSD38bMS  | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0.667             | 58.65       |
| Anem38yMS    | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0                 | 58.665      |
| AnemSD38yMS  | 26065                   | 15541                 | 59.624              | 0                  | 41.667         | 0                 | 58.665      |
| Anem20aMS    | 26065                   | 15523                 | 59.555              | 0                  | 35.333         | 0                 | 58.742      |
| AnemSD20aMS  | 26065                   | 15523                 | 59.555              | 0                  | 35.333         | 0                 | 58.742      |
| Vane50aDEG   | 26065                   | 15541                 | 59.624              | 0.167              | 65.333         | 0                 | 58.116      |
| VaneSD50aDEG | 26065                   | 15541                 | 59.624              | 0.167              | 65.333         | 0                 | 58.116      |
| Vane38aDEG   | 26065                   | 15541                 | 59.624              | 0.167              | 41.667         | 0                 | 58.661      |
| VaneSD38aDEG | 26065                   | 15541                 | 59.624              | 0.167              | 41.667         | 0                 | 58.661      |
| Vane20aDEG   | 26065                   | 15523                 | 59.555              | 0.5                | 35.333         | 0                 | 58.73       |
| VaneSD20aDEG | 26065                   | 15523                 | 59.555              | 0.5                | 35.333         | 0                 | 58.73       |
| Etmp2aDEGC   | 26065                   | 15541                 | 59.624              | 0                  | 0              | 0                 | 59.624      |
| EtmpSD2aDEGC | 26065                   | 15541                 | 59.624              | 0                  | 0              | 0                 | 59.624      |
| Total        | 573430                  | 341830                | 59.611              | 1.667              | 993.333        | 98                | 58.468      |

# **APPENDIX B - Plot Data**

#### **Wind Speed Distribution Data**

| Bin Center Wind Speed [m/s] | Percent of Time [%] |  |  |  |
|-----------------------------|---------------------|--|--|--|
| 0.5                         | 1.67                |  |  |  |
| 1.5                         | 3.09                |  |  |  |
| 2.5                         | 5.66                |  |  |  |
| 3.5                         | 10.9                |  |  |  |
| 4.5                         | 14.2                |  |  |  |
| 5.5                         | 14.21               |  |  |  |
| 6.5                         | 13.19               |  |  |  |
| 7.5                         | 11.29               |  |  |  |
| 8.5                         | 8.87                |  |  |  |
| 9.5                         | 6.87                |  |  |  |
| 10.5                        | 4.61                |  |  |  |
| 11.5                        | 3.09                |  |  |  |
| 12.5                        | 1.45                |  |  |  |
| 13.5                        | 0.51                |  |  |  |
| 14.5                        | 0.33                |  |  |  |
| 15.5                        | 0.07                |  |  |  |
| 16.5                        | 0.01                |  |  |  |
| 17.5                        | 0                   |  |  |  |
| 18.5                        | 0                   |  |  |  |
| 19.5                        | 0                   |  |  |  |
| 20.5                        | 0                   |  |  |  |
| 21.5                        | 0                   |  |  |  |
| 22.5                        | 0                   |  |  |  |
| 23.5                        | 0                   |  |  |  |
| 24.5                        | 0                   |  |  |  |

#### **Monthly Average Wind Speed Data**

| Date     | 10 min Mean [m/s] |
|----------|-------------------|
| Feb-06   | 6.78              |
| Mar-06   | 5.66              |
| April-06 |                   |
| May-06   | 5.62              |
| June-06  | 5.42              |
| July-06  | 5.50              |
| Aug-06   | 4.84              |
| Sept-06  | 5.02              |
| Oct-06   |                   |
| Nov-06   |                   |
| Dec-06   |                   |
| Jan-06   | 6.34              |
| Feb-06   | 6.44              |

# **Diurnal Average Wind Speed Data**

| Average Wind Speed |
|--------------------|
| [m/s]              |
| 5.87               |
| 5.77               |
| 5.99               |
| 6.07               |
| 5.98               |
| 6.07               |
| 6.15               |
| 6.33               |
| 6.31               |
| 6.49               |
| 6.53               |
| 6.61               |
| 6.68               |
| 6.74               |
| 6.9                |
| 6.78               |
| 6.35               |
| 6.16               |
| 6.04               |
| 5.84               |
| 5.69               |
| 5.78               |
| 5.77               |
| 5.92               |
|                    |

#### **Wind Rose Data**

|           | Percent Time | Mean Wind Speed |
|-----------|--------------|-----------------|
| Direction | [%], 49 m    | [m/s], 49 m     |
| N         | 3.34         | 3.76            |
| NNE       | 2.78         | 3.23            |
| NE        | 2.4          | 3.27            |
| ENE       | 1.69         | 4.71            |
| E         | 1.4          | 5.32            |
| ESE       | 1.6          | 5.2             |
| SE        | 1.87         | 5.25            |
| SSE       | 1.48         | 6.25            |
| S         | 1.78         | 6.33            |
| SSW       | 3.71         | 6.78            |
| SW        | 10.95        | 7.54            |
| WSW       | 11.47        | 5.96            |
| W         | 15.62        | 6.65            |
| WNW       | 16.98        | 6.63            |
| NW        | 16.16        | 6.73            |
| NNW       | 6.77         | 5.38            |